



Jim Doyle, Governor Mary P. Burke, Secretary

December 15, 2004

ALL AMERICAN HOMES INC PERRY LEHRMAN 309 S 13TH ST DECATUR IN 46733-0968 ALL AMERICAN HOMES, INC. JOHN MEYER 1551 15TH AVE S E PO BOX 219 DYERSVILLE IA 52040-0219

Re: Description: PREFABRICATED PLUMBING SYSTEM

Manufacturer: ALL AMERICAN HOMES, INC. Product Name: MADISON MODEL HOMES

Model Number(s): M2836 2 1 STD; M2836 2 1 B STD; M2836 2 1 2CGF STD; M2836 2 1 2CGF B STD;

M2858 2 1 2CGE STD; M2858 2 1 2CGE B STD

Product File No: 20040576

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2009.

This approval is contingent upon compliance with the following stipulation(s):

- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The flowing water pressure at the point(s) of connection must be at least 39 psi for M2836 2 1 STD and M2836 2
  1 B STD; 46 psi for M2836 2 1 2CGF STD and M2836 2 1 2CGF B STD; and 44 psi for M2858 2 1 2CGE STD and M2858 2 1 2CGE B STD

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 19990830.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742 fax: 608-267-9566

e-mail: mike.beckwith@wi.gov

SBD-10564-E (N.10/97) File Ref: 04057601.DOC